

State Water Resources Control Board

September 7, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7017 2680 0000 6289 4800

Mr. Ivan Sequeira
Facilities Manager
San Francisco Police Department
850 Bryant Street, Room 458
San Francisco, California 94103
ivansequeira@sfgov.org

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM
LOCATED AT SAN FRANCISCO POLICE DEPARTMENT MISSION STATION,
630 VALENCIA STREET, SAN FRANCISCO**

Dear Mr. Sequeira:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST at your facility on August 29, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Operating Permit Onsite – A valid UST operating permit was not available at the time of inspection.	All	August 29, 2018	Ongoing	H&SC 25284(a); 23 CCR 2712(i)
2	Failure to Maintain Tank Information – In CERS, the tank information did not list the following: tank installation date, method of overfill prevention, spill bucket, and striker plate.	All	August 29, 2018	Ongoing	23 CCR 2711(a)
3	Failure to Maintain Plot Plan/Site Map – In CERS, the site map did not identify the location of the underground piping.	All	August 29, 2018	Ongoing	23 CCR 2711(a)(8)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and San Francisco City & County Public Health Department within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Ms. Rebecca Green
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
rebecca.green@waterboards.ca.gov

Local CUPA

Mr. Jin Tang
Senior Environmental Health Inspector
San Francisco City & County Department of
Public Health
1390 Market Street, Suite 210
San Francisco, California 94102
jin.tang@sfdph.org

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: (via email only)

Mr. Ryan Schneider
Stationary Engineer
San Francisco City/County Police Department
ryan.schneider@sfgov.org

Ms. Paula Stewart
Program Manager
San Francisco City & County Public
Health Department
paula.stewart@sfdph.org

Mr. Jin Tang
Senior Environmental Health Inspector
San Francisco City & County Public
Health Department
jin.tang@sfdph.org